



DEVELOPMENT SERVICES
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: 08/14/17

City Project No.: 16-75

Addendum No.: 2

Plan holders:

The following changes and notations shall be made to the project specifications:

Project Specifications:

1. Exhibit 12-G
Exhibit 12-G shall be turned in no later than four working days after bid opening.
2. T-910 Hydro-Mulch
Clarification to specifications, Division 6, Item T-910 Hydro-Mulch, Mixture and Application Rates, page no. 283: Revise Item 4. Fiber application rate to 1,500 lbs. per acre.
3. Bidder's Form
Please replace bidder's form with the attached bidder's form. The attached bidder's form includes the section to acknowledge addendums.
4. Vault Size
The nominal size stated in addendum no.1 corresponds to the drawings and is the largest size precast building by the standard of performance manufacturer (Oldcastle Precast), specified on page 304, Item 109-2.2.n. that can occupy the foundation. Other precast buildings can certainly meet the requirements of L-109.

If you have any questions, please call me at (209) 668-6021 or email at RJones@turlock.ca.us.

Sincerely,

Randall Jones
Assistant Engineer

SCHEDULE OF BID ITEMS						
No.	SPEC.	CIVIL ITEM DESCRIPTION	QTY	UNIT	UNIT PRICE	EXT. TOTAL
1	GP-105	Mobilization (3% Max)	1	LS		
2	M-005-7.1	Airport Safety and Security	1	LS		
3	M-102-3.1	Construction Staking and Layout	1	LS		
4	M-103-3.1	Contractor Quality Control	1	LS		
5	M-105-4.1	Removal of Miscellaneous Improvements	1	LS		
6	M-145-5.1	Excavation Cut-Off Wall	2,990	LF		
7	M-150-4.1	Asphalt Concrete Removal by Milling (+/- 3")	10,350	SY		
8	M-150-4.2	Place, Blend, Compact Millings at Runway Shoulders	6,500	SY		
9	M-150-4.3	Apply Dust Palliative/Stabilizer Compacted Millings	6,500	SY		
10	M-215-5.1	Pre-Emergent Herbicide Application	19,000	SY		
11	M-215-5.2	Post Emergent Herbicide Application	1,500	LF		
12	M-220-7.1	Riprap Construction	25	SY		
13	P-101-5.1	Surface Preparation	1	LS		
14	P-101-5.2	Crack Sealing	1,500	LF		
15	P-151-4.1	Clearing and Grubbing	16.0	AC		
16	P-152-4.1	Unclassified Excavation	19,000	CY		
17	P-155-8.1	Lime-treated Subgrade	18,800	SY		
18	P-155-8.2	Lime (6%)	420	TON		
19	P-156-5.1	Storm Water Pollution Prevention Plan (SWPPP)	1	LS		
20	P-208-5.1	Crushed Aggregate Base Course (5")	12,300	SY		
21	P-403-8.1	Bituminous Surface Course	3,500	TON		
22	P-603-5.1	Bituminous Tack Coat	12	TON		
23	P-620-5.1	Runway and Taxiway Marking (with beads)	28,000	SF		
24	D-701-5.1	24-inch RGRCP, Class V	330	LF		
25	D-705-5.1	4-inch Perforated Edge Drain Pipe	3,200	LF		
26	D-705-5.2	8-inch Schedule 80 PVC Outlet Pipe	300	LF		
27	D-705-5.3	6-inch Schedule 80 PVC Outlet Pipe	1,400	LF		
28	D-705-5.4	4-inch Schedule 80 PVC Outlet Pipe	500	LF		
29	D-751-5.1	Catch Basins	1	EA		
30	D-752-5.1	Miscellaneous Drainage Structures (Dry Wells)	1	EA		
31	T-910-6.1	Hydro-Mulch	16	AC		

SCHEDULE OF BID ITEMS						
No.	SPEC.	ELECTRICAL ITEM DESCRIPTION	QTY	UNIT	Estimated UNIT PRICE	Total Item ESTIMATED COST
32	L-107-5.1	L-807, Style 1-A, Size 2 Wind Cone	1	EA		
33	L-107-5.2	Segmented Circle Marker System	1	EA		
34	L-108-5.1	No. 8 AWG L-824C Cable, installed in duct bank or conduit	10,500	LF		
35	L-108-5.2	Bare Counterpoise Wire, installed in trench, duct bank or conduit, including ground rods and ground connectors	6,400	LF		
36	L-108-5.3	Ground Conductor in Conduits, #6 THWN	7,550	LF		
37	L-109-5.1	Airport Transformer Vault and Foundation in Place	1	LS		
38	L-109-5.2	Electrical Service Connection and Utility Coordination Fee	1	LS		
39	L-109-5.3	Electrical Utility Fees	1	LS		
40	L-110-5.1	4-4 Inch Schedule 40 PVC Duct, Trenched, Concrete Encased	160	LF		
41	L-110-5.2	4-4 Inch Schedule 40 PVC Duct, Trenched, Un-encased	250	LF		
42	L-110-5.3	1-2 Inch Schedule 40 PVC Duct, Trenched, Un-encased	3,700	LF		
43	L-110-5.4	2-2 Inch Schedule 40 PVC Duct, Trenched, Un-Encased	2,710	LF		
44	L-110-5.5	2-2 Inch Schedule 40 PVC Duct, Trenched, Concrete Encased	300	LF		
45	L-110-5.6	4-2 Inch Schedule 40 PVC Duct, Trenched, Un-Encased	440	LF		
46	L-110-5.7	1-3 Inch and 2-4" inch Schedule 40 PVC Ducts for Utility Service, Trenched	160	LF		
47	L-110-5.8	2-2 Inch and 2-4" inch Schedule 40 PVC Ducts for Utility Service, Trenched	410	LF		
48	L-115-5.1	Electrical J-box-Handhole – Precast ID 4'x4'x4' – Used as a pullbox	9	EA		
49	L-115-5.2	L-867 Electrical Junction Base – Used as a splice can	2	EA		
50	L-115-5.3	TID Vault per Detail 1/E8.2	1	EA		
51	L-115-5.4	TID Transformer Pad and Bollards per Details 1, 2 and 3, Drawing E8.1	1	EA		
52	L-115-5.5	AT&T Pullboxes	2	EA		
53	L-125-5.1	Taxiway Edge Light – LED, On New Base	40	EA		
54	L-125-5.2	L-861 Runway Edge Light – LED, On New Base - (color per plan)	27	EA		
55	L-125-5.3	L-861SE Runway Threshold Light, Red/Green, On new Base.	12	EA		
56	L-125-5.4	New L-858 Size 1, 2 Module Sign, LED, New Sign Pad Installed	3	EA		
57	L-130-5.1	TVSS Installed	1	LS		

Total Bid _____

Total Bid
Amount is: _____ Dollars and _____ Cents

Bidder has examined and carefully studied the Bidding documents and other related data identified in the Bidding Documents and the following Addenda, receipt of which is hereby acknowledged.

Addenda

No. _____ Date: _____ Signed: _____

No. _____ Date: _____ Signed: _____

No. _____ Date: _____ Signed: _____

No. _____ Date: _____ Signed: _____

No. _____ Date: _____ Signed: _____

Contractor: _____