



DEVELOPMENT SERVICES
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: 07/13/18

City Project No.: 17-46

Addendum No.: 1

Plan holders:

See the list below for responses to questions received concerning the Sewer Lift Station #49 Pump Replacement project:

1. Ordering the pumps will require 3 weeks to issue and a 9-10 week lead time. Will the contractor be responsible for liquidated damages during that wait time?
 - a. Working days will be suspended from the date the pump is ordered until the start of construction. Liquidated damages will not apply to the time waiting for replacement pumps. Contractors shall schedule start of construction based on the anticipated delivery date of the pump.
2. What is the anticipated flow rates during construction?
 - a. Average influent flow rate at lift station #49 is 200 gpm.
3. Will the Performance and Payment bonds be 100% of the contract?
 - a. Yes, see Agreement for more details.
4. Will the proposed force main connection be done by the contractor or the City?
 - a. Contractor will connect the proposed force main to the existing force main.

The bid opening is still scheduled for Tuesday, July 17 at 2:00 as specified in the project documents. If you have any questions, please call me at (209) 668-5428 or email at ahutchings@turlock.ca.us.

Sincerely,

Adam Hutchings, PE
Associate Civil Engineer