



PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION
156 S. BROADWAY, SUITE 150
TURLOCK, CA 95380

PHONE: (209) 668-5520
FAX: (209) 668-5563
TDD: (800) 735-2929
engineering@turlock.ca.us

Date: 9/2/2022

Addendum No.: 1

City Project: 22-022, "HVAC Unit Replacements – Various Locations"

Plan holders:

The following clarifications shall be made to the project specifications:

Project Specifications:

1. **Question:** Do Valley Air District low-NOx requirements apply to unit replacements for this project?

Answer: Trane dual fuel RTUs are the basis of design. However, all gas fired heating furnace packaged units proposed in this project shall meet the ultra-low NOx < 14 ppm NOx requirements per the requirements of the San Joaquin Valley Air Pollution Control District. Other equipment may be approved if engineering review considers the substitution to be an approved equal.

If you have any questions, please call me at (209) 668-5599 x5417 or email at sfremming@turlock.ca.us.

Sincerely,

Stephen Fremming
Principal Civil Engineer