



---

156 S. BROADWAY, SUITE 270 | TURLOCK, CALIFORNIA 95380 | PHONE 209-668-5402 | FAX 209-668-5695

REQUEST FOR INFORMATION

BID NO. 24-001

FOR

GRANULAR ACTIVATED CARBON ADSORPTION SYSTEM CHANGE OUT SERVICES

INFORMATIONAL ADDENDUM NO. 1

DATED ISSUED: MAY 23, 2024

1. **The scope of work for this RFP calls for hydraulic loading of the activated carbon. These vessels hold 1,000 lbs of GAC. Hydraulic loading is impractical for vessels of this size. Is it acceptable to dry load the vessels either by emptying GAC bags directly into the vessels, or by vacuum transfer?**

Yes, both methods are acceptable.

2. **The RFP also calls for delivery of the GAC in trailers used solely for the transport of GAC. Other than pneumatic slurry tankers we do not have any trailers used solely for the transport of GAC. And even if we did, dedicating a trailer to transport 1,000 lbs of GAC would be prohibitively expensive. Is it acceptable to transport the virgin GAC in our service truck?**

Yes, it is acceptable.